TAB 11(a)



Rhode Island Department of Environmental Management

235 Promenade Street, Providence, RI 02908-5767

TDD 401-831-5508

January 23, 2002

Paul Calenda 472 Potters Avenue Providence, RI 02906

Re:

Underground Storage Tank Removal

Business & Rental Property

472 Potters Avenue Providence. RI

RI DEM Facility I.D. #19002

Dear Mr. Calenda:

The Office of Waste Management has reviewed a Closure Assessment Report for the above-referenced facility, prepared by FJA Environmental Associates, and dated January 10, 2002.

Based on the representations made by the consultant in the report and our inspector's observations at the time of removal, no further action is presently required by this Office. However, the D.E.M. reserves the right to order future corrective measures should any significant contamination in groundwater or soil become apparent.

Enclosed for your records is a Certificate of Closure for the closed underground storage tank(s).

Sincerely,

Bruce T. Catterall

Supervising Sanitary Engineer Office of Waste Management

BTC/ltd

CC:

Frank J. Abbatematteo, FJA Environmental Associates

UST Facility File

TAB 11(b)

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT UNDERGROUND STORAGE TANK SECTION

Providence, Rhode Island 02908 (401) 222-2797

UST FACILITY ID_	#19002
LUST FACILITY ID	A STATE OF

CLOSURE CERTIFICATE FOR UNDERGROUND STORAGE FACILITIES

In compliance with Chapter 46-12 of the Rhode Island General Laws, as amended, and the Regulations for Underground Storage Facilities Used for Petroleum Products and Hazardous Materials,

Business & Rental Property

owner/operator of an underground storage facility-located at

472 Potters Avenue Providence, RI

is issued this Certificate of Closure indicating that the storage tanks described below have been taken out of service permanently, in compliance with the Regulations for Underground Storage Facilities Used for Petroleum Products and Hazardous Materials.

TANK ID	VOLUME	STORED MATERIAL	DATE LAST USED	STATUS OF TANK
				F=Filled R=Removed
001	1500 gal.	gasoline		R
003 005	1500 gal.	gasoline qasoline		R
004 005	500 gal.	gasoline gasolive		R R
006	500 gel.	gasoline		8
007 008	500 gal. 5000 gal.	gasoline fuel oil		R
Signed this _		24th day		, 20 <u>02</u>
Approved:		Boult Co	thalf	
		age Tank Section		
Del	parument of En	vironmental Managemen	ıt.	18.

NOTE: This is not a document to approve or certify that tanks are/were safe or clean to transport.

USCLOSCT.MST